



Qá|ãá Lamon  
 METH SRL  
 Via Fondovilla, 84/F  
 36010 CARRE VI ITALY

Date: 2017/07/11  
 Subscriber: None  
 PartySite: 1664080  
 File No: E215141  
 Project No: 17SR4196084  
 PD No: 17M25836  
 Type: R  
 PO Number:

Subject: **Procedure And/Or Report Material**

The following material resulting from the investigation under the above numbers is enclosed.

**Issue**

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
2001/07/23	1	1	Cert of Compliance	
2002/07/25	1	2	Cert of Compliance	
2012/04/17	1	3	Cert of Compliance	
2016/01/19	1	4	Cert of Compliance	
2016/08/08	1	5	Cert of Compliance	

Carlo Filippi, UL INSPECTION CENTER ITALY, UL ITALIA INC, VIA DELLE INDUSTRIE 1,  
 Field Engineering Services ; Italy  
 T:: +39 0292526606  
 F:: +39 0292526501  
 M:: +39 3669068799, EMAIL: carlo.filippi@ul.com

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://ul.com/aboutul/locations>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above.

This material is provided on behalf of UL LLC (UL) or any authorized licensee of UL.

MEL File

UL INSPECTION CENTER 357

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170711-E215141  
**Report Reference** E215141-20010723  
**Issue Date** 2017-JULY-11

**Issued to:** METH SRL  
VIA FONDOVILLA, 84/F  
36010 CARRE VI ITALY

**This is to certify that  
representative samples of**

COMPONENT - SYSTEMS, ELECTRICAL INSULATION  
Class 155(F) transformer insulation system designated  
METH.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

UL 1446, Systems of Insulating Materials - General  
CSA C22.2 NO 0-10, General requirements — Canadian  
Electrical Code, Part II

**Additional Information:**


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog  
number, model number or other product designation as specified under "Marking" for the particular  
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products  
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  
 may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is  
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual  
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance  
capabilities and are intended for use as components of complete equipment submitted for investigation rather  
than for direct separate installation in the field. The final acceptance of the component is dependent upon its  
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170711-E215141  
**Report Reference** E215141-20020725  
**Issue Date** 2017-JULY-11

**Issued to:** METH SRL  
VIA FONDOVILLA, 84/F  
36010 CARRE VI ITALY


**This is to certify that representative samples of** COMPONENT - SYSTEMS, ELECTRICAL INSULATION Class 130(B) insulation system designated B.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1446, Systems of Insulating Materials - General  
CSA C22.2 NO 0-10, General requirements — Canadian Electrical Code, Part II


**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170711-E215141  
**Report Reference** E215141-20120417  
**Issue Date** 2017-JULY-11

**Issued to:** METH SRL  
VIA FONDOVILLA, 84/F  
36010 CARRE VI ITALY

**This is to certify that  
representative samples of**

COMPONENT - SYSTEMS, ELECTRICAL INSULATION  
Class 155 (F) transformer insulation system designated  
METH-2.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

UL 1446, Systems of Insulating Materials - General  
CSA C22.2 NO 0-10, General requirements — Canadian  
Electrical Code, Part II

**Additional Information:**


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog  
number, model number or other product designation as specified under "Marking" for the particular  
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products  
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  
 may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is  
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual  
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance  
capabilities and are intended for use as components of complete equipment submitted for investigation rather  
than for direct separate installation in the field. The final acceptance of the component is dependent upon its  
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170711-E215141  
**Report Reference** E215141-20160119  
**Issue Date** 2017-JULY-11

**Issued to:** METH SRL  
VIA FONDOVILLA, 84/F  
36010 CARRE VI ITALY

**This is to certify that  
representative samples of**

COMPONENT - SYSTEMS, ELECTRICAL INSULATION  
Class 155 (F) transformer insulation system designated  
METH-3.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

UL 1446, Systems of Insulating Materials - General  
CSA C22.2 NO 0-10, General requirements — Canadian  
Electrical Code, Part II

**Additional Information:**


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog  
number, model number or other product designation as specified under "Marking" for the particular  
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products  
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  
 may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is  
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual  
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance  
capabilities and are intended for use as components of complete equipment submitted for investigation rather  
than for direct separate installation in the field. The final acceptance of the component is dependent upon its  
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170711-E215141  
**Report Reference** E215141-20160808  
**Issue Date** 2017-JULY-11

**Issued to:** METH SRL  
VIA FONDOVILLA, 84/F  
36010 CARRE VI ITALY

**This is to certify that  
representative samples of**

COMPONENT - SYSTEMS, ELECTRICAL INSULATION  
Class 180 (H) transformer insulation system designated  
METH-4.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:**

UL 1446, Systems of Insulating Materials - General  
CSA C22.2 NO 0-10, General requirements — Canadian  
Electrical Code, Part II

**Additional Information:**


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog  
number, model number or other product designation as specified under "Marking" for the particular  
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products  
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  
 may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is  
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual  
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance  
capabilities and are intended for use as components of complete equipment submitted for investigation rather  
than for direct separate installation in the field. The final acceptance of the component is dependent upon its  
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

